

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1108/D/SWA/NSA

Dated: 18/3/2024

It is certified that an inspection team headed by Mrs. ALKA SINGH - CHEMIST

(Name of Officers with designation) from KANPUR NAGAR NIGAM

(Name of Department/ Office) inspected the GURU NANAK MODERN SCHOOL, BAIRI-AKADARPUR KACHAR KANPUR

(Name & Address of the school) on 07/3/2024 (date of inspection) and found that the GURU NANAK MODERN SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of ONE YEAR

Signature with Seal: M/नगर स्वास्थ्य अधिकारी

Name: Dr. Anur Singh Kaur

Designation: N.S.A.

Name & Address of the Office / Department :

To
GURU NANAK MODERN SCHOOL
BITHOOR ROAD, KALYANPUR KANPUR

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY, KANPUR NAGAR NIGAM

Chemical water analysis report for the M/s GURU NANAK MODERN SCHOOL, Beiri Akbarpur Kacher, Kalyanpur Kanpur

Sample taken from	Submersible
Date of sample Drawn	07/3/2024
Date of analysis	07/3/2024
Physical Character	Transparent / odourless
P. H. Value	8.46
Free Ammonia Parts per 1000000	Nil
Alouninoid Ammonia Part per 1000000	Nil
Oxygen absorbed from pot. Permagnate in three hours at 37° C	0.00
Chloride Part per 1000000	64.00
Nitrates Parts per 1000000	Nil
Nitrates Parts per 1000000	Nil
Total solid part per 100000	680.00
Fixed solid Parts per 1000000	570.00
Volatils solid Parts per 100000	110.00
Appearance on ignition	No Charring
Total hardness Parts per 1000000	184.00
Permanent hardness Parts per 1000000	152.00
Temporary hardness Parts per 1000000	32.00

Remarks :

"POTABLE"

No. 333/Sw/chem dated 16/03/2024

Copy forwarded for fovour or information to

1) M/s GURU NANAK MODERN SCHOOL
Beiri Akbarpur Kacher, Kalyanpur

2) N.S.A. Kanpur Nagar Nigam.

Nagar Swasthya Adhikari

Nagar Nigam Kanpur

ALKA SINGH

(Chemist)

Nagar Nigam Kanpur



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY NAGAR NIGAM KANPUR

Result of Bacteriological Examination of Water Sample taken from

Name & designation of the person collecting samples

D. No.:- 333/SW/Chem 16/03/2024

u/s Gurus Nanak Modern School, Beini, Akaberpur, Kacher, Bithoor Road, Kanpur Nagar

Atka Singh - Chemist - (K-410)

Date & time of collection	Source of sample	Colony count on Agar Agar per M. L. of water		Presumptive Coliform count				Probable on of coliform organism in 100 CC of original water	Free Residual Chlorine part per Million	REMARKS
		at 37.c in 48 hours	at room temp-rature in 72 hours	Quantity of water put in each tube No of tubes put up	50ML 1	10 ML 5	1 ML 5			
07/3/2024	Submersible	10	34	—	Nil	Nil	Nil	Zero	Nil	Good

Copy for Information Forwarded to

- (1) u/s Gurus Nanak Modern School
Beini Akaberpur, Kacher, Kanpur
- (2) N.S.A. Kanpur Nagar Nigam.

ALKA SINGH
(Chemist)
Nagar Nigam Kanpur